

VOC Content Test Certificate

Friday July 10th, 2009

Manufacturer: Ductmate Industries Inc (Charleroi, Pennsylvania USA)

Australian Distributor: Ductware, a Division of RMD Industries Pty Ltd (Melbourne, Sydney, Brisbane, Adelaide, Perth)

Sample Description: Proseal (high velocity duct sealant)

Date Tested: July 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Proseal
Architectural Sealant 250 grams per Litre as VOC content material	<1 gram per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Proseal
Architectural Sealant 250 grams per Litre as VOC content material	<1 gram per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0907-04